


**JE-H(ST)H
E30**
**Halogen-Free and Flame Retardant Installation Cable
for Industrial Electronics with Circuit Integrity
of 30 Minutes**
Application:

Suitable for fixed installations in telecommunication. They are to be used in locations with fire hazard and where insulation integrity of at least 180 minutes and circuit integrity of at least 30 minutes are required.


Construction:

- 1 solid bare copper
- 2 core insulation of halogen-free, similar ceramic polymer compound, Cores twisted to pairs and four twisted pairs in a bundle, bundle identification by Number characteristic helix (Z) or ring mark on core insulation (Si)
- 3 layer of plastic foil
- 4 static screen of plastic coated metal foil with a solid tinned drain wire 0,8mm
- 5 outer sheath of halogen-free polymer (HM 2), orange

Information:

These cables fulfil the conditions of the tests to insulation integrity according to DIN VDE 0472-814/ 8.83 about 180 min. and IEC Public. 331 first edition 1970 to circuit integrity about 30 min. to DIN 4102-12 according to VDE 0100-710 and 0100-718.

Standards:

- DIN VDE 0815 (core identification)
 DIN EN 60228 class 1 (construction)
 DIN VDE 0207-24

Technical data:

Peak operating voltage		[V]	225 Volt
Temperature range	in motion fixed		- 5°C till +50°C -30°C till +70°C
Bending radius	in motion	x diameter	7,5
Flammability	standard		EN 50266-2-4 EN 60332-1
			IEC 60332-3 Kat.C
Insulation resistance	standard	[MOhm/km]	100
Mutual capacitance	min.	[Ohm/km]	73,2
	max.	[nF/km]	120
Capacitance unbalance 100m	max	[pF]	200

Number of pairs and nominal conductor diameter mm	Copper figure kg/km	Insulation thickness mm	Overall diameter appr. mm	Calorific potential kWh/m	Weight appr. kg/km
2 x 2 x 0,8	24,0	1,0	6,6	0,13	86
4 x 2 x 0,8	43,2	1,0	8,8	0,20	138
8 x 2 x 0,8	81,6	1,2	12,8	0,34	220
12 x 2 x 0,8	121,0	1,2	13,5	0,39	298
20 x 2 x 0,8	197,8	1,4	16,1	0,53	465
32 x 2 x 0,8	326,4	1,4	20,6	0,85	704

The above values correspond to the manufacturer's specifications and are not guaranteed.

TESLA KABELI d.o.o.

Industrijska 20 | 10431 Sveti Nedelja | Croatia
 Tel: +385 (0)1 2362-900 | Fax: +385 (0)1 2362-901
info@teslacables.com | www.teslacables.com

TESLA KABELI d.o.o. BEOGRAD

Nehruova 51a/100 | 11070 Novi Beograd | Serbia
 Tel: +381 11 3177-096 | GSM: +381 64 2630-500
stevan.kugli@teslacables.com | www.teslacables.com

Member of

